



TOWN OF RYE SEWER COMMISSION
P.O. Box 544, 830 Central Road, 2nd Floor, Rye Beach, NH 03871
(603) 964-6815, sewer@town.rye.nh.us

APPLICATION FOR SECONDARY USAGE WATER METER

DATE: _____ 20 ____

NAME: _____

MAILING ADDRESS: _____

HOME TELEPHONE: _____ MOBILE: _____

E-MAIL: _____

INSTALLATION ADDRESS: _____

PURPOSE FOR METER: _____

METER TYPE AND SERIAL #: _____

DATE OF INSTALLATION: _____

INSPECTED AND APPROVED BY CLERK-OF-WORKS: (Date, etc.)

INITIAL READING: _____

FINAL READING: _____

ADJUSTMENT TO WATER BILL: _____

DATE: _____ AMOUNT OF CREDIT CU. FT. _____

DATE: _____ AMOUNT OF CREDIT CU. FT. _____

DATE: _____ AMOUNT OF CREDIT CU. FT. _____

ATTEST: _____

DATE: _____

Article 12

1200 Installation and Usage of Water Meters for Accessory Water Usage:

The Sewer Commission shall have the authority to control the installation and usage of water meters to measure the accessory or incidental usage of water by a sewer user, but not entering the public sewer system. Such usage would include irrigation, swimming pools, etc.

1201 Technical Requirements:

A water meter installed by a landowner to measure water usage not entering the Public Sewer System shall meet the following minimum industry standards:

1. Meets or exceeds the latest AWWA standard C 700-77.
2. Sturdy, durable corrosive resistant.
3. Resist internal pressure stresses and external damage.
4. Handles in-line piping variations and stresses.
5. Incorporates a residual valve.
6. Electrical grounding continuity.
7. Has a 1:1 ratio, a low flow indicator detects leaks.
8. Tamper-proof seals.
9. Direct read, magnetic drive, roll sealed.

1202 Water Meters:

The Neptune T-10 or Hershey water meters are approved for installation. A suitable substitute may be used; however, it must be approved by the Sewer Commission Clerk-of-the-Works for installation.

1203 Installation and Location:

Water meters will be installed at the owners expense under the direction of the Rye Sewer Commission. The water meter shall be easily accessible for reading.

1204 Permit Fee

A permit fee of Ten Dollars (\$10.00) shall be assessed each user for each installed water meter and shall include the initial and final water usage readings.

1205 Readings and Recording Water Meters

At the initial seasonal usage and the end of the third quarter the meter will be read, and usage recorded by a representative of the Sewer Commission. The final reading of the meter may be prior to the end of the third quarter at the users request.

1206 Adjustment to Water Bill:

The reading taken in Paragraph 1205 above will be used to annually adjust the sewer use bill submitted to each user in the fourth quarter.

i.e. Hampton Water Co. Reading 2000 cu. ft.
Water used under Paragraph 1205.... 500 cu. ft.
Charge for sewer usage 1500 cu. ft.

1207 Other:

Any water discharged and metered for non-sewer use shall not be redirected into the sewer system.

ADDENDUM TO ARTICLE 12:

Section 1202 – Badger water meters are approved.
There must be a remote (outside) reader denoting cubic ft.

Section 1203 –

- (A) Must have a vacuum-breaker
- (B) Must have a Building Permit from building department
- (C) Must use a license installer
- (D) Must have a meter reader denoting cubic ft. that is located outside.
- (E) Must have a back-flo preventor

